

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50466428

Blatt *Sheet*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum <i>Date of Issue</i>
Z.G.L.	01-Wuchale-60367703 001	28.04.2020 (day/mo/yr)

Genehmigungsinhaber *License Holder*

Wenzhou Arrester Electric Co., Ltd.
5th FL, No. 666 Yaming Road,
Xiangyang Industry Park, Liushi,
Yueqing
325604 Zhejiang
P. R. China

Fertigungsstätte *Manufacturing Plant*

Wenzhou Arrester Electric Co., Ltd.
5th FL, No. 666 Yaming Road,
Xiangyang Industry Park, Liushi,
Yueqing
325604 Zhejiang
P. R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

EN 61643-11:2012+A11

Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)*

Lizenzentgelte - Einheit *License Fee - Unit*

Surge Protector (Surge Protective Device)

Type Designation: 1) FLP25-275/1+1, FLP25-275/1S+1
2) FLP25-275/2+1, FLP25-275/2S+1
FLP25-275/3+1, FLP25-275/3S+1
3) FLP25-275/1, FLP25-275/1S
FLP25-275/2, FLP25-275/2S
FLP25-275/3, FLP25-275/3S
FLP25-275/4, FLP25-275/4S

8

Trade mark : **LSP**
Uc : 1) & 2) : AC 275 V (L-N), AC 255 V (N-PE)
3) : AC 275 V (L/N-PE)
In/Imax : 25 kA/100 kA
Iimp : 1) : 25 kA (L-N), 50 kA (N-PE)
2) : 25 kA (L-N), 100 kA (N-PE)
3) : 25 kA (L/N-PE)
Up : 1.5 kV (L-N), 1.5 kV (N-PE)
Isccr : 50 kA
Type of SPD : Type 1 + Type 2
IP Code : IP20
Location : Indoor
Temperature : -40°C to 70°C

8

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des Zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax.: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Bo Liu